



Massachusetts Department of Environmental Protection
Bureau of Waste Prevention – Industrial Wastewater
BWP IW 38 & BWP IW 39
Permit for Industrial Sewer User

W204098
Transmittal Number

Facility ID# (if known)

ATTACHMENT A

Special Conditions:

1. The permittee shall maintain compliance with the Town of Westborough's sewer use requirements and the terms and conditions of any applicable wastewater discharge permits issued by the Westborough-Shrewsbury Wastewater Treatment Plant.
2. The permittee shall comply with the Effluent Guidelines and Standards at 40 CFR, Chapter I, Subchapter N, Part 469 – Electrical and Electronic Components Point Source Category, and applicable subcategories.
3. The permittee shall notify MassDEP of additional Effluent Guidelines and Standards as they are determined to be applicable to the facility.
4. The Specific Prohibitions on Page 11 shall include at the end of part d., "concentration that will cause interference with the POTW or its wastewater collection system." and "e. Heat in amounts which may inhibit biological activity in the POTW, resulting in interference. In no case shall heat in such quantities that the temperature at the POTW treatment plant exceeds 40° C (104° F) be discharged, unless the Department, upon request of the POTW, approves alternate temperature limits."
5. The Additional Conditions on Page 12 shall include at the end of part j., "wastewater treatment system operation or wastewater discharge, for purposes of conducting activities related to oversight of this permit, including inspections to monitor compliance with the terms herein. The permittee shall allow the Department to obtain information related to compliance with the requirements of this permit. Notwithstanding any provision of this permit, the Department retains all of its access authorities and rights under applicable state and federal law.
6. The documents and materials attached to and referenced in the permit application are incorporated as part of the permit.